

San Juan Public Lands Dolores Ranger District/Field Office



Engine 8653 is a Type 6 Wildland Fire Engine. The engine requires A three person crew and must meet The following requirements.

A Type 6 Engine must have a Water tank of at least 150 gallons, and a pump that can pump at least 50 Gal per minute at 100 PSI. It must carry 300 feet of 1 1/2 inch hose and 300 feet of 1 inch hose.



San Juan Public Lands Dolores Ranger District/Field Office



Engine 8452 is a Wildland Type 4 Engine. The engine also must Have a 3 person crew as a minimum. The other requirements are listed below:

Have a tank that can carry a Minimum of 750 gallons of water. And a pump that can pump 50 gall. Per min. at 100 PSI. Also carry 300 feet of 1 1/2 inch hose along with 300 feet of 1 inch hose.

